

Mecklenburg County Common Code Defects

Electrical

Code Defects

Circuit Shorted out

Code Description

110.7 Insulation Integrity.

Completed wiring installations shall be free from short circuits and from grounds other than as required or permitted in Article 250.

Disclaimer: There may be other ways to comply with the Code. If so, you are not required to use this method to comply with the Code. You may want to investigate other options, or consult with a design professional identifying an equally code compliant solution.

End Notes

National Electrical Code

National Electrical Code Committee and National Fire Protection Association Inc.

Anaheim, CA August 2, 2001